



On Start-up, lamp will warm up for 15 minutes on Bright before responding to Force Bright or Force Low commands.

Notes:

1. Multiple fixtures with common switched control.
2. Order G2-LB-x with optional -EXTP1 port.
3. Force lights Bright or Low through DPDT low-voltage switch.
4. No Occupancy-based condition.

G2 / EXTP1 - Force High/Force Low



Building Automation, Inc.

internal note: G2 / EXTP1 - Force High/Force Low can control ~100 fixtures if wired cleanly