


- Notes:
1. Lights turn ON if either sensor detects occupancy
  2. Lights turn OFF only after BOTH sensors time out

IWSZP3P wired as 3-way
 <b>Building Automation, Inc.</b>