



## Sensors connected in parallel loops

Notes:

1. Lights turn OFF only after BOTH sensors time out.
2. This is a ground-leakage powered sensor. It must be grounded to function.
3. The Residential Occupancy Sensor is for incandescent Lighting and CFL Lighting.

RWSOSCFL in a 3-way Configuration



Building Automation, Inc.