



Sensors connected in parallel loops

Notes:

1. Lights turn ON when manual button is pushed.
2. Lights turn OFF only after BOTH sensors time out.
3. This is a ground-leakage powered sensor. It must be grounded to function.
4. The Residential Vacancy Sensor is **incandescent Lighting and CFL Lighting**.

RWSVSCFL in a 3-way Configuration



Building Automation, Inc.